

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated April 13, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room location: Jacobs Memorial Library, Illinois Valley Community College, Oglesby, Illinois 61348.

Detroit Edison Company, Docket No. 50-341, Fermi-2, Monroe County, Michigan

Date of application for amendment: July 29, 1993, as supplemented October 8, 1993.

Brief description of amendment: The amendment revises the Technical Specification ACTION STATEMENTS related to operability of the control room emergency filtration system. A portion of the amendment request was denied. A separate Notice of Denial of Amendment has been sent to the **Federal Register** for publication.

Date of issuance: March 31, 1995.

Effective date: March 31, 1995, with full implementation within 45 days.

Amendment No.: 103.

Facility Operating License No. NPF-43. Amendment revises the Technical Specifications.

Date of initial notice in Federal Register: August 18, 1993 (58 FR 43925). The October 8, 1993, letter provided clarifying information within the scope of the original submittal and did not change the staff's initial no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated March 31, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room location: Monroe County Library System, 3700 South Custer Road, Monroe, Michigan 48161.

Duke Power Company, Docket Nos. 50-369 and 50-370, McGuire Nuclear Station, Units 1 and 2, Mecklenburg County, North Carolina

Date of application for amendments: January 18, 1995.

Brief description of amendments: The amendments revise TS Table 4.3-3 to allow the analog channel operational test interval for radiation monitoring instrumentation to be increased from monthly to quarterly, and are consistent with the guidance in Generic Letter 93-05, "Line-Item Technical Specifications Improvements to Reduce Surveillance Requirements for Testing During Power Operation."

Date of issuance: April 3, 1995.

Effective date: As of the date of issuance to be implemented within 30 days.

Amendment Nos.: 154 and 136.

Facility Operating License Nos. NPF-9 and NPF-17. Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: March 1, 1995 (60 FR 11132).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated April 3, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room location: Atkins Library, University of North Carolina, Charlotte (UNCC Station), North Carolina 28223.

Entergy Operations, Inc., Docket No. 50-368, Arkansas Nuclear One, Unit No. 2, Pope County, Arkansas

Date of application for amendment: July 22, 1993.

Brief description of amendment: The amendment revised operability requirements for the Reactor Protection System and the Engineered Safety Features Actuation System.

Date of issuance: April 3, 1995.

Effective date: April 3, 1995.

Amendment No.: 159.

Facility Operating License No. NPF-6. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: September 1, 1993 (58 FR 46229).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 3, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room location: Tomlinson Library, Arkansas Tech University, Russellville, AR 72801.

Florida Power and Light Company, Docket Nos. 50-250 and 50-251, Turkey Point Plant, Units 3 and 4, Dade County, Florida

Date of application for amendments: July 19, 1994, resubmitted October 20, 1994, and supplemented February 20, 1995.

Brief description of amendments: These amendments relate to the maximum allowable reactor thermal power operation with inoperable main steam safety valves.

Date of issuance: April 11, 1995.

Effective date: April 11, 1995.

Amendment Nos.: 172 and 166.

Facility Operating Licenses Nos. DPR-31 and DPR-41. Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: November 23, 1994 (59 FR 60380).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated April 11, 1995. The February 20, 1995 submittal provided additional information that did not change the staff's proposed no significant hazards consideration determination.

No significant hazards consideration comments received: No.

Local Public Document Room location: Florida International University, University Park, Miami, Florida 33199.

IES Utilities Inc., Docket No. 50-331, Duane Arnold Energy Center, Linn County, Iowa

Date of application for amendment: October 28, 1994.

Brief description of amendment: The amendment revised the license by deleting the "Plan for the Integrated Scheduling of Plant Modifications for the Duane Arnold Energy Center," as a condition of the license.

Date of issuance: April 3, 1995.

Effective date: April 3, 1995.

Amendment No.: 208.

Facility Operating License No. DPR-49. Amendment revised the license.

Date of initial notice in Federal Register: March 1, 1995 (60 FR 11134).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 3, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room location: Cedar Rapids Public Library, 500 First Street SE., Cedar Rapids, Iowa 52401.

Maine Yankee Atomic Power Company, Docket No. 50-309, Maine Yankee Atomic Power Station, Lincoln County, Maine

Date of application for amendment: December 6, 1994, as supplemented on February 27, and April 4, 1995.

Brief description of amendment: The amendment revises the Technical Specifications to allow the use of the Combustion Engineering sleeving process for repairing steam generator tubes. (The current requirement specifies that degraded steam generator tubes be repaired by plugging.)

Date of issuance: April 14, 1995.

Effective date: As of the date of issuance, to be implemented within 30 days.

Amendment No.: 149.

Facility Operating License No. DPR-36. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: January 18, 1995 (60 FR 3673). The February 27, and April 4, 1995,