

Specification (TS) 1.7, "CORE ALTERATION," to state that movement or replacement of incore instrumentation is not considered to be a CORE ALTERATION and that movement of control rods is not considered a CORE ALTERATION provided there are no fuel assemblies in the associated core cell. This amendment includes changes to TS 3/4.9.3, "Control Rod Position," and associated Bases to be consistent with the revision to TS 1.7. TS 3/4.9.3 is being revised to require that all control rods be inserted only during loading of fuel assemblies into the core rather than during CORE ALTERATIONS. These changes are consistent with the NRC's, "Improved Standard Technical Specifications," (NUREG-1434).

This amendment also revises Item 1.i.3) of TS Tables 3.3.2-1 and 4.3.2.1-1 to delete the requirement for Reactor Water Cleanup isolation due to actuation of the Standby Liquid Control System (SLCS) in OPERATIONAL CONDITION 5. License Amendment No. 48 issued on September 30, 1993, deleted the requirement for the SLCS to be OPERABLE in OPERATIONAL CONDITION 5; however, due to an oversight, Item 1.i.3) and associated notations were not deleted from TS Tables 3.3.2-1 and 4.3.2.1-1 as part of License Amendment No. 48. This amendment corrects that oversight.

Date of issuance: January 20, 1995.

Effective date: As of the date of issuance to be implemented within 30 days.

Amendment No.: 61.

Facility Operating License No. NPF-69: Amendment revises the Technical Specifications.

Date of initial notice in Federal

Register: November 23, 1994 (59 FR 60382).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 20, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room

location: Reference and Documents Department, Penfield Library, State University of New York, Oswego, New York 13126.

Niagara Mohawk Power Corporation, Docket No. 50-410, Nine Mile Point Nuclear Station, Unit 2, Oswego County, New York

Date of application for amendment: November 14, 1994.

Brief description of amendment: The amendment revises Technical Specification 4.5.1.e.2.e) to reduce the leak rate test pressure for the Automatic

Depressurization System (ADS) nitrogen receiving tanks from 385 psig to 365 psig.

Date of issuance: January 31, 1995.

Effective date: As of the date of issuance to be implemented within 30 days.

Amendment No.: 62.

Facility Operating License No. NPF-69: Amendment revises the Technical Specifications.

Date of initial notice in Federal Register: December 21, 1994 (59 FR 65817).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 31, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room

location: Reference and Documents Department, Penfield Library, State University of New York, Oswego, New York 13126.

North Atlantic Energy Service Corporation, Docket No. 50-443, Seabrook Station, Unit No. 1, Rockingham County, New Hampshire

Date of amendment request: January 14, 1994, as modified by letter dated October 17, 1994.

Description of amendment request: The amendment revises the Appendix A Technical Specifications (TS) to specify the composition of the Station Operation Review Committee (SORC) based on experience and expertise vice organizational position, to implement a Station Qualified Reviewer Program (SQRP), and to revise the time within which the Nuclear Safety Audit Review Committee (NSARC) must issue reports and minutes.

The amendment also incorporated a number of editorial changes to delete certain items that are no longer applicable; remove inconsistencies involving the names of systems, equipment and NSARC function, composition, and use of alternates; and correct the value for the reactor coolant system volume. Other editorial changes have been incorporated for document format consistency. The amendment affects the following: TS Sections 1.31, 3.3.3.6, 3.4.1.2, 4.6.3.2, 3.7.1.2, 3/4 10.6, 5.4.2, 6.3.1, 6.4, 6.7, and 6.8.1.4, and Table 4.3-1.

Date of issuance: January 26, 1995.

Effective date: January 26, 1995.

Amendment No.: 34.

Facility Operating License No. NPF-86: Amendment revised the Technical Specifications.

Date of initial notice in Federal

Register: May 25, 1994 (59 FR 27057)
The licensee's letter dated October 17,

1994, provided clarification and minor revision to the application but does not change the initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 26, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room

location: Exeter Public Library, 47 Front Street, Exeter, NH 03833.

Northeast Nuclear Energy Company, et al., Docket No. 50-423, Millstone Nuclear Power Station, Unit No. 3, New London County, Connecticut

Date of application for amendment: July 22, 1994.

Brief description of amendment: The amendment revises the Technical Specifications to incorporate a different setpoint and transient methodology for determining the maximum allowable power range neutron flux setpoint. These changes allow Millstone Unit 3 to operate with a reduced number of main steam-line safety valves at a reduced power level, as determined by the high flux setpoint.

Date of issuance: January 31, 1995.

Effective date: As of the date of issuance to be implemented within 30 days.

Amendment No.: 102.

Facility Operating License No. NPF-49: Amendment revised the Technical Specifications.

Date of initial notice in Federal

Register: September 14, 1994 (59 FR 47171).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 31, 1995.

No significant hazards consideration comments received: No.

Local Public Document Room

location: Learning Resources Center, Three Rivers Community-Technical College, Thames Valley Campus, 574 New London Turnpike, Norwich, CT 06360.

Pennsylvania Power and Light Company, Docket Nos. 50-387 and 50-388 Susquehanna Steam Electric Station, Units 1 and 2, Luzerne County, Pennsylvania

Date of application for amendments: October 25, 1994.

Brief description of amendments: These amendments add to the Susquehanna, Units 1 and 2, Technical Specifications, isolation signals to Table 3.6.3-1 for the containment isolation valves on the sample lines for the containment radiation monitoring and